



No. :

Date :



Certificate of Analysis

Aluminum Sulfate

SR	Property	Units	Limit	RESULT	Analiz metodu
1	Al ₂ O ₃	% w/w Min	17	17.06	INSO 3096
2	pH 1 %	% w/v Min	3	3.24	INSO 3096
3	Insoluble	% w/w Max	0.1	0.08	INSO 3096
4	Free H ₂ SO ₄	% w/w Max	0.00	0.00	Turkish
5	Free Al ₂ O ₃	% w/w Max	0.23	0.019	Turkish
6	Fe ₂ O ₃	% w/w Max	0.03	0.026	INSO 3096

P E T R O A R S E S C o .

✉ info@petroarses.com  www.petroarses.com

  (+98 912) 650 85 53